CERTIFICATE OF EMC

CERTIFICATE NO.: SET2015-01567

Product:	Main board
Model:	BL2000-STB-V* (*=9-9.99, indicate the different customer or/and Software function number)
Applicant:	ShenYang Bluelight Automatic Technology Co., Ltd.
Address:	No. 37 Shiji Road, Hunnan New District, Shenyang, China

This is to certify that, on the basis of the tests undertaken as per Report No. **SET2015-01567**, the submitted sample of the above item complies with:

EN61000-6-4:2007+A1:2011
EN61000-6-2:2005

and fulfils testing requirement of the EMC directive 2004/108/EC

Signed for and on behalf of
CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.

Wu Li An, Vice Director

Date of Issue: Feb. 06, 2015

CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.
Building 2&29, Shiji Industrial Park, Shiji Street, Nanshan District,
Shenzhen, Guangdong, China
Tel:86-755-26627338 Fax:86-755-26627238 http://www.ccic-set.com

[redacted]

[redacted]

查询码：6PA7ZR5b

Report No.








Table of Contents

Report.....2

1 General Information.....5

1.1 Description of EUT.....5

4.5 Electrical Fast Transient/Burst Immunity Test 14

4.5.1 Test Specification 14

4.5.2 Test Setup 14

4.5.3 Test Result 15

4.6 Surge Immunity Test 1

4.6.1 Test Specification 1

4.6.2 Test Setup 1

4.6.3 Test Result 1

4.7 Immunity to Conducted Disturbances Induced by RF Fields 16

4.7.1 Test Specification 16

4.7.2 Test Setup 16

4.7.3 Test Result 16

4.8 Power Frequency Magnetic Field Immunity Test 17

4.8.1 Test Specification 17

4.8.2 Test Setup 17

4.8.3 Test Result 17

Appendix I Photographs of the EUT 18

Appendix II Photographs of EMC Test Configuration 19

1 General Information

1.1 Description of EUT

Product:	Main board
Model No.:	BL2000-STB-V9.0
Brand Name:	/
Serial No.:	/
Rating:	Input: 5V DC, 24V DC
Accessories:	/


NOTE:

1. For more detailed features description about the EUT, please refer to User's Manual.
2. Application model is BL2000-STB-V* (*=9-9.99, indicate the different customer or and Software function number). Models differences do not affect the performance of EMC. All tests

2.3 Test Standards and Results

The EUT has been tested according to the following specifications





3 Emission Test

3.1 EUT Setup and Operating Conditions

The EUT was powered by 5V DC and 24V DC mains. The EUT was continuously operated during the test.

3.2 Radiated Disturbance Measurement

3.2.1 Limits of Radiated Disturbance

Frequency range (MHz)	Quasi peak limits(dBμV/m), at 10m measurement distance
30 –230	40
230 - 1000	47


Notes:

(1) The lower limit shall apply at the transition frequency.

(2) Additional provisions may be required for cases where interference occurs.

3.2.2Test Setup





1. Electromagnetic radiation disturbances, max peak detector, antenna polarization: Vertical

2. Electromagnetic radiation disturbances, max peak detector, antenna polarization: Horizontal

4 Immunity Test

4.1 EUT Setup and Operating Conditions

Same as 3.1.

4.2 Performance Criteria


Criterion A	The apparatus shall continue to operate as intended. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
Criterion B	The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
Criterion C	Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls

4.3 Electrostatic Discharge Immunity Test

4.3.1 Test Specification

Basic Standard:	IEC 61000-4-2
Discharge Impedance	330 Ω / 150 pF
Discharge Voltage:	Air Discharge: 8 kV Contact Discharge: 4kV
Polarity:	Positive / Negative
Number of Discharge:	Minimum 20 times at each test point
Discharge Mode:	Single discharge
Discharge Period:	1-second minimum
Criterion:	B






4.4 Radiated, Radio Frequency Electromagnetic Field Immunity Test

4.4.1 Test Specification

Basic Standard:	EN 61000-4-3		
Frequency Range:	80 MHz-1000MHz	1.4GHz-2.0GHz	2.0GHz-2.7GHz
Field Strength:	10V/m	3V/m	1V/m
Modulation:	1kHz sine wave, 80%, AM modulation		
Frequency Step:	1% of fundamental		
Polarity of Antenna	Horizontal and Vertical		
Test Distance:	3m		
Antenna Height:	1.5m		
Dwell Time:	3 seconds		
Criterion:	A		

4.4.2 Test Setup



4.4.3 Test Result

Frequency	Polarity	Azimuth	Field Strength (V/m)	Observation	Comply with Criterion
80-1000 MHz	V&H	0,90, 80, 270	10	Note(1)	A
1.4-2.0GHz	V&H	0,90, 80, 270	3	Note(1)	A
2.0-2.7GHz	V&H	0,90, 80, 270	1	Note(1)	A

NOTE:

(1). The EUT continued to operate as intended. No degradation of performance was observed.

4.5 Electrical Fast Transient/Burst Immunity Test

4.5.1 Test Specification

Basic Standard: IEC 61000-4-4

For the actual test configuration, please refer to Appendix II – Photographs of the Test Configuration.

4.5.3 Test Result

Test Point	Polarity	Test Level (kV)	Observation	Comply with Criterion
DC. power	+/-	2	Note (1)	A
Signal port	+/-	1	Note (1)	A

NOTE:


(1). The EUT continued to operate as intended. No degradation of peformance as observed.

4.6 Surge Immunity Test

4.6.1 Test Specification

Basic Standard:	IEC 61000-4-5
Waveform:	Voltage 1.2/50 μs; Current 8/20 μs
Test Voltage:	DC power port line to line 0.5 kV, line to earth 0.5 kV
Polarity:	Positive/Negative
Repetition Rate:	60sec
Times:	5 time/each condition.
Criterion:	B

4.6.2 Test Setup



4.6.3 Test Result

Coupling Line	Polarity	Voltage (kV)	Observation	Comply with Criterion
DC power Line-Line	+/-	0.5	Note (1)	A

NOTE:

(1). The EUT continued to operate as intended. No degradation of peformance as observed.

4.7 Immunity to Conducted Disturbances Induced by RF Fields

4.7.1 Test Specification

Basic Standard:	IEC 61000-4-6


4.8 Power Frequency Magnetic Field Immunity Test

4.8.1 Test Specification

Basic Standard:	IEC 61000-4-8
Frequency Range:	50Hz

Appendix I ÖPhotographs of the EUT

Appendix II ÖPhotographs of EMC Test Configuration



5. Electrical Fast Transient/Burst Immunity Test

6. Surge Immunity Test

7. Immunity to Conducted Disturbances Induced by RF Fields

8. Power Frequency magnetic Field Immunity

STATEMENT

This test laboratory is accredited by CNAS, Accreditation Certificate No.L1659.

2. **The test report is invalid without stamp of laboratory.**
3. **The test report is invalid without signature of person(s) testing and authorizing.**
4. **The test report is invalid if erased and corrected.**
5. **Test results of the report is valid to the test samples if sampling by client.**
6. **¿ item cannot be Accredited by CNAS.**
7. **The test report shall not be reproduced except in full, without written approval of the laboratory.**
8. **If there is any objection to report, the client should inform issuing laboratory within 15 days from the date of receiving test report.**

Address: Building 28/29, Shigudong, Xili Industrial Area, Xili Street, Nanshan District, Shenzhen, Guangdong, China P.C. Ö518055

TEL Ö0755-26628093 Ã26627338 FAX Ö0755-26627238

Internet Öhttp://www.ccic-set.com E-Mail Ömanager@ccic-set.com